

测试报告

编号 : GZMR101019368
日期 : 2010.10.11
页码 : 1 of 2

上海市沃勒建材有限公司
上海市青浦区联民路 1881 号 2 栋 1 层 B 区 119 室


下列样品由客户提供及确认:

样品名称 : 黑白根 (Negro Maquina)
样品信息 : 原料产地: 中国
SGS 参考号 : XMML100903291, GP100920230-22.16
测试要求 : 根据客户要求选择测试
收样日期 : 2010 年 09 月 20 日
测试周期 : 2010 年 09 月 20 日至 2010 年 10 月 11 日

测试结果 : 请见下页
测试结论 : 经测试, 该样品放射性核素限量符合标准 GB 6566-2001 中 A 类装饰材料规定要求, 其产销与使用范围不受限制。

*****待续*****

通标标准技术服务有限公司
授权签名



彭卫玲 技术主管

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at <http://www.sgs.com/termsandconditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained here on reflects the technical findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a warranty or a guarantee for the transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced except in full without the prior approval of the Company.

测试报告

编号 : GZMR101019368

日期 : 2010.10.11

页码 : 2 of 2

放射性核素

测试方法:

GB 6566-2001 建筑材料放射性核素限量

样品描述:

大理岩, 见图片

测试结果:


检验项目	技术要求 (A类)	检验结果
内照射指数 I_{Ra}	$I_{Ra} \leq 1.0$	0.08
外照射指数 I_{γ}	$I_{\gamma} \leq 1.3$	0.12

放射性核素比活度

放射性核素	单位	放射性比活度
镭-226	贝可/千克 (Bq/kg)	16.63
钍-232		11.19
钾-40		131.44

备注: 以上测试项目是在厦门实验室进行。

样品照片:



*****报告结束*****

This document is issued by the Company under its General Conditions of Service printed overleaf or available on request and accessible at <http://www.sgs.com/termsandconditions.htm>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained here on reflects the technical findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced except in full without the prior approval of the Company.



198 KEZHU Road, SOFTECH Park, Guangzhou Economic & Technology Development District, Guangzhou, China 510663
 t (86-20)82155555 f (86-20)82075080 www.cn.sgs.com
 中国·广州·经济技术开发区科学城科珠路198号 邮编:510663 t (86-20)82155555 f (86-20)82075080 e sgs.china@sgs.com

GZMR